SIEMENS

Data sheet



SCALANCE XB216 managed Layer 2 IE switch, 16X 10/100 Mbit/s RJ45 ports, 1x console port, diagnostics LED redundant power supply IEC 62443-4-2 certified; temperature range 0 °C to +60 °C; DIN-rail mounting, PROFINET IO device Ethernet/IP certificate, default PROFINET.

product type designation	SCALANCE XB216
transfer rate	
transfer rate	10 Mbit/s, 100 Mbit/s
number of ports / maximum	16
interfaces / for communication / integrated	
number of electrical connections	
 for network components or terminal equipment 	16; RJ45
interfaces / other	
number of electrical connections	
 for operator console 	1
 for management purposes 	1
for power supply	1
type of electrical connection	
 for operator console 	RJ11
for management purposes	RJ45
supply voltage, current consumption, power loss	
product component / connection for redundant voltage supply	Yes
type of voltage / 1 / of the supply voltage	DC
 supply voltage / 1 / rated value 	24 V
power loss [W] / 1 / rated value	6.7 W
supply voltage / 1 / rated value	19.2 28.8 V
consumed current / 1 / maximum	0.28 A
 type of electrical connection / 1 / for power supply 	6-pole terminal block
 product component / 1 / fusing at power supply input 	Yes
ambient conditions	
ambient temperature	
during operation	0 60 °C
during storage	-40 +70 °C
during transport	-40 +70 °C
relative humidity	
at 25 °C / without condensation / during operation / maximum	95 %
protection class IP	IP20
design, dimensions and weights	
design	Box
width	80 mm
height	117 mm
depth	109 mm

	0.41
net weight	0.4 kg
material / of the enclosure	Plastic
fastening method	V
35 mm top hat DIN rail mounting	Yes
product features, product functions, product components	
cascading in the case of a redundant ring / at reconfiguration time of <\~0.3\~s	50
cascading in cases of star topology	any (depending only on signal propagation time)
product functions / management, configuration, engineeri	ng
product function	
• CLI	Yes
 web-based management 	Yes
 MIB support 	Yes
 TRAPs via email 	Yes
configuration with STEP 7	Yes
• RMON	Yes
• port mirroring	Yes
multiport mirroring	No
• CoS	Yes
PROFINET IO diagnosis	Yes
PROFINET conformity class	В
product function / switch-managed	Yes
telegram length / for Ethernet / maximum	1522 byte
protocol / is supported	
• Telnet	Yes
• HTTP	Yes
• HTTPS	Yes
• TFTP	Yes
• FTP	Yes
• DCP	Yes
• LLDP	Yes
• EtherNet/IP	Yes
• SNMP v1	Yes
• SNMP v2	Yes
• SNMP v3	Yes
 IGMP (snooping/querier) 	Yes
identification & maintenance function	
• I&M0 - device-specific information	Yes
 I&M1 – higher level designation/location designation 	Yes
product functions / diagnostics	
product function	
• port diagnostics	Yes
statistics Packet Size	Yes
statistics packet type	Yes
error statistics	Yes
SysLog	Yes
loopback diagnostics	Yes
product functions / VLAN	
product function	
VLAN - port based	Yes
product functions / DHCP	
product function	
DHCP client	Yes
	100
product functions / redundancy	
product function	V
• ring redundancy	Yes
High Speed Redundancy Protocol (HRP)	Yes
 high speed redundancy protocol (HRP) with redundancy manager 	Yes
	Vos
 high speed redundancy protocol (HRP) with standby 	Yes

redundancy	
protocol / is supported / Media Redundancy Protocol	Yes
(MRP)	
product function	
 media redundancy protocol (MRP) with redundancy manager 	Yes
 Media Redundancy Protocol Interconnection (MRP-I) 	Yes
• redundancy procedure STP	Yes
redundancy procedure RSTP	Yes
• redundancy procedure RSTP+	Yes
 Parallel Redundancy Protocol (PRP)/operation in the PRP-network 	Yes
passive listening	Yes
protocol / is supported	
• LACP	Yes
product functions / security	
product function	
ACL - MAC-based	Yes
ACL - port/MAC-based	Yes
• IEEE 802.1x (radius)	Yes
broadcast/multicast/unicast limiter	Yes
broadcast blocking	Yes
protocol / is supported	
• SSH	Yes
• SSL	Yes
product functions / time	
product function	V
SICLOCK support	Yes
NTP-client	Yes
SNTP client	Yes
protocol / is supported	V
• SNTP	Yes
standards, specifications, approvals	
standard	
• for FM	FM3611: Class 1, Divison 2, Group A, B, C, D / T4, CL.1, Zone 2, GP. IIC, T4
• for safety / from CSA and III	
 for safety / from CSA and UL for emitted interference 	UL 60950-1, CSA C22.2 No. 60950-1 EN 61000-6-4 (Class A)
	EN 61000-6-4 (Class A) EN 61000-6-2
• for interference immunity	
IT security for industrial automation systems / according to IEC 62443-4-2:2019	Yes
reference code	VE.
according to IEC 81346-2	KF
• according to IEC 81346-2:2019	KFE
standards, specifications, approvals / CE	
certificate of suitability / CE marking	Yes
certificate of suitability / RoHS conformity	Yes; 2011/65/EU
standards, specifications, approvals / hazardous environn	nents
standard / for hazardous zone	EN 60079-0 : 2006, EN 60079-15: 2005, II 3 G Ex nA II T4 KEMA 07
• from CSA and UL	ATEX 0145X
	ATEX 0145X ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8
certificate of suitability	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
certificate of suitability • CCC / for hazardous zone according to GB standard	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A,
CCC / for hazardous zone according to GB standard	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 Yes EN 61000-6-2, EN 61000-6-4
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability C-Tick	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 Yes EN 61000-6-2, EN 61000-6-4 Yes
CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability C-Tick KC approval	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 Yes EN 61000-6-2, EN 61000-6-4
 CCC / for hazardous zone according to GB standard standards, specifications, approvals / other certificate of suitability C-Tick 	ANSI / ISA 12.12.01, CSA C22.2 No. 213-M1987, CL. 1 / Div. 2 / GP. A, B, C, D T4, CL. 1 / Zone 2 / GP. IIC, T8 Yes EN 61000-6-2, EN 61000-6-4 Yes

• to web page: selection aid TIA Selection Tool

• to website: Industrial communication

• to website: Industry Mall

• to website: Information and Download Center

• to website: Image database

• to website: CAx-Download-Manager

• to website: Industry Online Support

http://www.siemens.com/tia-selection-tool

http://www.siemens.com/simatic-net

https://mall.industry.siemens.com

http://www.siemens.com/industry/infocenter

http://automation.siemens.com/bilddb

http://www.siemens.com/cax

https://support.industry.siemens.com

security information

security information

Siemens provides products and solutions with industrial security functions that support the secure operation of plants, solutions, machines, equipment and/or networks. They are important components in a holistic industrial security concept. With this in mind, Siemens' products and solutions undergo continuous development. Siemens recommends strongly that you regularly check for product updates. For the secure operation of Siemens products and solutions, it is necessary to take suitable preventive action(e.g. cell protection concept) and integrate each component into a holistic, state-of-the-art industrial security concept. Third-party products that may be in use should also be considered. For more information about industrial security, visit http://www.siemens.com/industrialsecurity. To stay informed about product updates as they occur, sign up for a product-specific newsletter. For more information, visit http://support.automation.siemens.com. (V3.4)

last modified:

5/11/2022