

Resistance Repeater KCD2-RR2-Ex1

- 1-channel isolated barrier
- 24 V DC supply (Power Rail)
- Resistance and RTD input (Pt100, Pt500, Pt1000)
- Resistance output
- Accuracy 0.1 %
- Line fault detection (LFD) for Pt100
- Housing width 12.5 mm
- SIL 2 (SC 3) acc. to IEC/EN 61508



Function

This isolated barrier is used for intrinsic safety applications.

It transfers resistance values of RTDs or potentiometers from hazardous areas to safe areas. A 2-, 3-, or 4-wire technique is available depending on the required accuracy. The input card of the control system measures the same load as if it were connected directly to the resistance in a hazardous area.

Connection



Technical Data

General specifications		
Signal type		Analog input
Functional safety related parameters		
Safety Integrity Level (SIL)		SIL 2
Systematic capability (SC)		SC 3
Supply		
Connection		Power Rail or terminals 9+, 10-
Rated voltage	Ur	19 30 V DC
Ripple		within the supply tolerance
Rated current	l _r	< 28 mA
Power consumption		0.35 W (24 V and 1 mA sense current), 0.85 W (30 V and 10 mA sense current)

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Pepperl+Fuchs Group www.pepperl-fuchs.com



Technical Data

Input		
Connection side		field side
Connection		terminals 1 2 3 4
Line fault detection		ves at Pt100
Lead resistance		< 10 % of resistance value
Transmission range		
		7 V
Line fault detection		< 30 nA
Connection side		control side
Connection		terminals 5- 7- $6\pm$ 8+
Current		0 10 mA
Available voltage		0 42V
Fault signal		field voltage $< 150 \text{ mV} \text{ or } > 4 \text{ V}$ depending on lead disconnected
Powerce polarity protection		for $l < 10 \text{ mA or } l < 20 \text{ V}$
Transfor characteristics		
		0.1.9/
Deviation		0.1%
Deviation		$I_m \ge 1$ mA: ±0.1 % of R_m of ±0.1 Ω (the larger value is applicable) $I_m < 1$ mA: accuracy reduces in proportion to I_m . e. g. $I_m = 0.1$ mA: ±1 % of R_m or 1 Ω (the larger value is applicable).
Influence of ambient temperature		$I_m ≥ 1 \text{ mA}$, $R_m ≥ 100 \Omega$: 0.01 %/K in the range -20 +70 °C (-4 158 °F) $I_m < 1 \text{ mA}$ or $R_m < 100 \Omega$: temperature stability reduces in proportion to I_m or R_m
Settling time		≤ 5 ms
Rise time/fall time		≤ 2 ms (10 90%)
Galvanic isolation		
Output/power supply		functional insulation, rated insulation voltage 50 V AC
Indicators/settings		
Display elements		LED
Control elements		DIP switch
Configuration		via DIP switches
Labeling		space for labeling at the front
Directive conformity		
Electromagnetic compatibility		
Directive 2014/30/EU		EN 61326-1:2013 (industrial locations)
Conformity		
Electromagnetic compatibility		NE 21:2017 EN IEC 61326-3-2:2018
Degree of protection		IEC 60529:2001
Protection against electrical shock		UL 61010-1:2012
Ambient conditions		
Ambient temperature		-40 70 °C (-40 158 °F)
Mechanical specifications		
Degree of protection		IP20
Connection		screw terminals
Mass		approx. 100 g
Dimensions		12.5 x 119 x 114 mm (0.5 x 4.7 x 4.5 inch) (W x H x D) , housing type A2
Mounting		on 35 mm DIN mounting rail acc. to EN 60715:2001
Data for application in connection with hazar	dous ar	eas
EU-type examination certificate		BASEEFA 10 ATEX 0061X
Marking		© II (1)G [Ex ia Ga] IIC ℗ II (1)D [Ex ia Da] IIIC ℗ I (M1) [Ex ia Ma] I
Input		[Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I
Voltage	Uo	9.5 V
Current	1	39.22 m∆

Refer to "General Notes Relating to Pepperl+Fuchs Product Information"

Resistance Repeater

KCD2-RR2-Ex1

Technical Data		
Power	Pa	93 mW
Supply	. 0	
Maximum safe voltage	Um	250 V (Attention! The rated voltage can be lower.)
Output		,
Maximum safe voltage	Um	250 V (Attention! The rated voltage can be lower.)
Certificate		BASEEFA 10 ATEX 0062X
Marking		ll 3G Ex ec IIC T4 Gc
Galvanic isolation		
Input/Output		safe electrical isolation acc. to IEC/EN 60079-11:2007, voltage peak value 375 ${\rm V}$
Input/power supply		safe electrical isolation acc. to IEC/EN 60079-11:2007, voltage peak value 375 V
Directive conformity		
Directive 2014/34/EU		EN IEC 60079-0:2018 , EN 60079-7:2015+A1:2018 , EN 60079-11:2012
International approvals		
FM approval		
FM certificate		FM 19 CA 0039 X , FM 19 US 0067 X
Control drawing		116-0457 (cFMus)
UL approval		E106378
Control drawing		116-0332 (cULus)
IECEx approval		
IECEx certificate		IECEx BAS 10.0024X IECEx BAS 10.0025X
IECEx marking		[Ex ia Ga] IIC , [Ex ia Da] IIIC , [Ex ia Ma] I Ex ec IIC T4 Gc
General information		
Supplementary information		Observe the certificates, declarations of conformity, instruction manuals, and manuals where applicable. For information see www.pepperl-fuchs.com.

Assembly



Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

3

KCD2-RR2-Ex1

Matching	System Com	ponents

KFD2-EB2	Power Feed Module
UPR-03	Universal Power Rail with end caps and cover, 3 conductors, length: 2 m
UPR-03-M	Universal Power Rail with end caps and cover, 3 conductors, length: 1,6 m
UPR-03-S	Universal Power Rail with end caps and cover, 3 conductors, length: 0.8 m
K-DUCT-BU	Profile rail, wiring comb field side, blue
K-DUCT-BU-UPR-03	Profile rail with UPR-03- * insert, 3 conductors, wiring comb field side, blue

Accessories

	KC-ST-5GN	Terminal block for KC modules, 2-pin screw terminal, green
	KC-ST-5BU	Terminal block for KC modules, 2-pin screw terminal, blue
~	EBP 2- 5	Insertion bridge for connectors, 2-pin, fully insulated
*	KF-CP	Red coding pins, packaging unit: 20 x 6

 Refer to "General Notes Relating to Pepperl+Fuchs Product Information".

 Pepperl+Fuchs Group
 USA: +1 330 486 0002
 Getwww.pepperl-fuchs.com
 ga-info@us.pepperl-fuchs.com
 ga-info@us.pepperl-fuchs.com

4



Switch position

Switch	Input	Position
S1	2-wire technique	II
	3-wire technique	I
	4-wire technique	II

Factory settings: switch 1, in position I

Refer to the next section for connection information.

Additional Information

Function

When a signal converter, a DCS or PLC is connected to terminals 5, 6, 7, and 8 (control side), the measuring current is transferred to terminals 2 and 4 (field side). The resulting voltage at terminals 1, and 3 is transferred to terminals 5, 6, 7, and 8. In the case of fast multiplex input cards, transmission problems might be experienced in connection with low resistance values and/or high sensor currents. For data see rise time.

f

O

1 🗖

2 Β **S1**

The quoted accuracy is for a 4-wire technique connection. The accuracy in 3-wire technique will depend on the matching of the line resistance.

Connection types control side (safe area)



Connection types field side (hazardous area)

The resistance in the hazardous area can be measured with a 2-, 3- or 4-wire technique.

Pepperl+Fuchs Group www.pepperl-fuchs.com



Resistance Repeater

- 2-wire technique:
- Link terminals 1 and 2 and terminals 3 and 4. Connect the resistance to terminal 4 and terminal 2. Switch S1 in the position II. • 3-wire technique:
- Link terminals 1 and 2. Connect the resistance to terminals 3 and 4 and terminal 2. Switch S1 in the position I. • 4-wire technique

Connect the resistance to terminals 3 and 4 and terminals 1 and 2. Switch S1 in the position II.

Measurement range

The resistance repeater can convey a maximum of 10 mA and a maximum of 4.2 V. The maximum connectable resistance value can be calculated with the following equation: resistance value = 4.2 V / measuring current

The measuring current is determined by control.



An example of the maximum transferable resistance value:

- 4.2 kΩ at 1 mA measuring current
- 420 Ω at 10 mA measuring current

Line Fault Detection (LFD)

The output will indicate less than 15 Ω or greater than 400 Ω for a lead breakage at terminals 1, 2, 3 or 4 for measuring current of less than or equal to 10 mA i. e. out of range for Pt100.

